



www.rotaflow.ca

| FACILITY: |  |
|-----------|--|
| LOCATION: |  |

| STATIC | RES    | TIME       | STATIC          | RES                    | TIME                       | STATIC                          | RES                                    | TIME                                       | STATIC  | RES  | TIME   |
|--------|--------|------------|-----------------|------------------------|----------------------------|---------------------------------|--|--|---|--|--|
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  | <br>                                       |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        |        |            |                 |                        |                            |                                 |  |  |   |  |  |
|        | STATIC | STATIC RES | STATIC RES TIME | STATIC RES TIME STATIC | STATIC RES TIME STATIC RES | STATIC RES TIME STATIC RES TIME | STATIC RES TIME STATIC RES TIME STATIC | STATIC RES TIME STATIC RES TIME STATIC RES | STATIC RES TIME STATIC RES TIME STATIC RES TIME | STATIC RES TIME STATIC RES TIME STATIC RES TIME STATIC | STATIC RES TIME STATIC RES TIME STATIC RES TIME STATIC RES |

## **INSTRUCTIONS:**

- 1. Record initial static pressure using supply water gauge.
- 2. Fully open main drain valve (usually 2 in.) until flow has stabilized and record residual pressure
- 3. Close valve and record time for water pressure to return to originalstatic pressure.

Conduct test annually on all sprinkler risers in the facility. If the sole water supply is through a backflow preventer and/or pressure reducing valves, test at least one system on a quarterly basis.

A large drop in the full flow pressure of the main drain (as compared to previous tests) normally is indicative of a dangerously reduced water supply caused by a valve in an almost fully closed position or other type of severe obstruction. After closing the drain a slow return to normal static pressure is confirmation of the suspicion of a major obstruction in the waterway and should be considered sufficient reason to determine the cause of the variation.